*The specifications are subject to changes without notice. *The company reserves the right of final interpretation and correction Version 1.0

COSUPER

USER MANUAL







Trading Company: Suzhou Cosuper Energy Technology CO.,LTD Manufacturer: Suzhou Develpower Energy Equipment Co.,LTD

Add: No.99 Gangtian Road, Suzhou Industrial Park,215121,China Tel: +86 512 68638910 Fax: +86 512 68638916 E-mail: info@cosuper.com Web: www.cosuper.com



>> TABLE OF CONTENTS

1. Attention1
2. Product introduction1
3. Panel figure2
4. Feature2
5. Installation and connection instruction3
6. CPW indication instruction
7. Controller status ·····8
8. System voltage alternative8
9. System protection function description9
10. Operating mode
11. Error instruction and description11
12. Parameters instruction12
13. Accessories
14. Warranty13

1.Attention

Warning: This controller is a high power device, please read the instruction before use, take extra care when operating.

Safety notes:

(1)read the instruction and attention carefully before use

(2)Do not disassembly and repair the controller freely

(3) Avoid direct sunlight and pay attention to ventilation When installation

(4)Install appropriate fuse or circuit breaker on the outside of the controller

(5)Disconnect the external fuse or circuit breaker when wiring

(6)Be careful to prevent short-circuit when installing the battery

 $(7) \mathrm{To}$ ensure adopt the correct wire diameter, connect firmly, fasten the wire after connection

(8)Temperature resistance should be fixed on the battery, the othe end connect to the controller

2.Product introduction



This controller is designed for DC power supply system, small and medium-sized pv modules power system, using a dedicated computer chip to realize the intelligent control, all chips adopt industrial level, can be used in harsh environment. Meanwhile system offers specific indication for the charge, load, sorts of failure and various protections such as short circuit, over-load, over charge, particular anti-reversed polarity protection and so on, the controller used computer chip to sample the parameter of the battery voltage, photovoltaic cell voltage, discharge current and environment temperature. According to the battery's character, realized the accurate control to discharge rate, correction of the temperature compensation through special control model calculation.charging with the intelligent PWM dim way and charging compensation in accordance with the current temperature of the battery, compensation factor is 3mv/C'/unit.LCM could show all of the parameters and modes. Dial switch need to adjust if adopting different voltage system.

3. Panel figure

(1) Panel figure



4.Feature

(1) The controller carried with CPW module which can display system status and parameters

(2) Begin to ascending charging automatically when the voltage of battery below the ascending charging recover voltage

(3) Temperature compensation become more accurate due to Double temperature sensors design, inner temperature sensor test the inner temperature of the controller, outer temperature sensor test the outer temperature of the controller.

(4) The controller could figure out everyday's power of charge and discharge which make user assess the controller and entire system more easily

(5) With the charging current overload protection function, the controller will reduce the charge current to protect the charging circuit after it surpass the rated current.

(6) A equalizing charge every 30 days in order to prevent battery vulcanization(7) Industrial-grade chips and precision components makes the controller can operate in any harsh environment

(8) Design of double MOS series control circuit and PWM dim control make the charging efficiency increased greatly

(9) The setting parameter possess the saving function which makes the parameter won't be erased after losing the electricity and system become more reliable.

(10) Three kinds of load work mode: purely light-operated, light-operated+time controlled, long-term on mode.

5.Installation and connection instruction

(1) Installation of controller must be reliable, size is as follows: ① 45A Boundary and Installation dimension



② 30A Boundary and Installation dimension



③Preparation of the wire:

Adopt the wire matching the current, plan the length of wire, strip 5mm insulation of one side of the controller's terminal and try to decrease the length of the connected wire so that a reduction in electrical loss.

4Battery connection

Pay attention to the pole +, -, do not connect reversely. If connect correctly, the controller will start to work or it's necessary to check the wire connection and battery's situation. Users could connect the system followed by the order showed in the below figure.

⑤Photovoltaic module connection

Pay attention to the pole +, -, if sun light is tested, photovoltaic indicator will light on or it's necessary to check the connection.

⑥Load connection

Connect the load wire with the controller's output terminal, the current can't surpass the controller's rated current and pay attention to the +, - pole, for avoiding damage to the device, do not connect reversely

⑦Temperature sensor connection

Connect one side of the temperature sensor to controller, the other side to the battery. There must be a good thermal contact with the battery shell.





6. CPW indication instruction

The controller adopts segmentation CPW indicator which could show 7 items parameters (1) Overall figure

Param 4th Param 2nd Param 3rd Param 1st Auto recoginze indictor. Input current indicator IN 48V system indictoroutput current indicator OUT 36V system indictor-•Unit: K/A/H/°C KAH°C 24V system indictor-Unit: K/V/W/% 12V system indictor-Solar panel Abnormal batterv load setting indicator indicator indicator indicator indicator

(2) Displayed page

Screen initialize firstly then show kinds of system's parameters when power on.

Photovoltaic array current

This page shows the pv array real-time current



② Battery voltage

This page show the real-time battery voltage.



③ Load current

This page show the real-time load current



④ Battery temperature

This page show the real-time controller's inner temperature



⑤ Charge power on the day

This page show the real-time charge power on the day



⑥ Discharge power on the day This page show the real-time discharge power on the day



Word mode This page show the real-time work mode



⑧ Fault warning

This page show the corresponding error code when system abnormal occurs, return to normal display after cancel the error



(3) Mode operation and parameter browse

①Parameter preview

Click the button: switch to next display page

Long press the button: long press the button in non-work mode page start the auto CPW switch display.

② Working mode setting

Positioning the work mode page according to the "parameter preview" Long press button: long-press in work page, click to user's required mode after the number blink, long-press for a period of time to exit with saving the parameter automatically, CPW switch to display again automatically after exit.



ATTENTION: switch automatically—It's not necessary to participate for users, CPW will swich to next page automatically every 3s.



LedLigh	Always off	Always on	twinkle Slow	twinkle fast
PV array instruction	Night	Daytime	In charging	System over voltage
Load instruction	Load off	Load on	Overload	Short circuit

8. System voltage alternative

Before setting, please kindly check the system voltage. This controller support 12/24/36/48V system. Please choose the voltage before use.

	Truth	п Та	ble
	System	Posi	tion
	120	Ŧ	Ŧ
	240	Ť	Ť
	360	Ť	Ţ
$1 \subset$	48V	1	1

System voltage	dial switch state	Description
12V	Down Down	The right and left gear both turn to Upward.
24V	Down Up	Turn the left gear to Downward, Turn the right gear to Upward
36V	Up Down	Turn the left gear to Upward, Turn the right gear to Downward
48V	Up Up	The right and left gear both turn to Upward

9.System protection function description

(1)Overtemperature protection

Controller temperature exceed 90 $^{\circ}$ C will close the load and charging efficiency will decrease. Temperature less than 85 $^{\circ}$ C will recover.

Battery temperature exceed 55°C will close the load and charging will closed. Temperature less than 55°C will recover.

(2)Charging protection

Decrease the charging efficiency when PV array charging current more than Rate charging current and less then 1.25 times of Rate charging current for 60s.

Decrease the charging efficiency when PV array charging current more than 1.25 and less then 1.5 times of Rate charging current for 5s.

Decrease the charging efficiency when PV array charging current more than 1.5 times of Rate charging current for 1s.

Recover after decrease charging efficiency for 1 min.

(3)Over discharge protection

The controller will start the over discharge protection and close the load when the battery voltage is less than over discharge voltage and duration 5s.

The controller will start the over discharge recovery protection when the battery voltage exceed the over discharge recovery voltage. The next night will remove automatically.

(4)Short circuit protection

Short circuit:

The first time short circuit in one day will recover after 5s later.

The second time will recover after 10s later.

The third time will recover after 15s later.

The forth time will recover after 20s later.

The fifth time or more than five times will recover after 4hours later.

Also can recover by long press the key!

(5)Over load protection

Over-load protection:

Close the load when load current more than Rate load current also less than 1.25 times of Rate load current for 60 seconds;

Close the load when load current more than 1.25 also less than 1.5 times of Rate load current for 30 seconds;

Close the load when load current more than 1.5 also less than 3 times of Rate load current for 5 seconds;

Recovery normal after overload stop 60s later, not have the limited times.

(6)Reverse connection protection

This controller including the PV array, battery and load reverse connection protection.

10.Operating mode

LED Display	Mode	LED Display	Mode
00	Purely light-operated	08	Light-operated + time- controlled for 8 hours
01	Light-operated + time- controlled for 1 hour	09	Light-operated + time- controlled for 9 hours
02	Light-operated + time- controlled for 2 hours	10	Light-operated + time- controlled for 10 hours
03	Light-operated + time- controlled for 3 hours	11	Light-operated + time- controlled for 11 hours
04	Light-operated + time- controlled for 4 hours	12	Light-operated + time- controlled for 12 hours
05	Light-operated + time- controlled for 5 hours	13	Light-operated + time- controlled for 13 hour
06	Light-operated + time- controlled for 6 hours	14	Light-operated + time- controlled for 14 hours
07	Light-operated + time- controlled for 7 hours	15	Always on mode

11. Error instruction and description

Error code	Fault description	Solutions and recovery condition	CPW display	Led display
E1	Too high of controller temperature	Please ensure the solar panel and load power not exceeded the rate power then place the controller to ventilation environment. Auto recover after temperature decrease. Controller will decrease the charging efficiency and close discharge.	Bat and PV twinkle at the same time	
E2	Battery over voltage	Please check right connection and voltage of the battery	Bat twinkle	Solar panel indicator twinkle fas
E3	Battery over discharge	Ensure the input voltage of the battery is normal. Recover auto after full charge	Bat twinkle	
E4	Excessive charging current	Please check the solar panel power whether exceed the controller's rate power	Pv twinkle	
E7	Load short circuit	Ensure the output line of the load not have short circuit. After eliminate the faults then long press the key or hold on it will recover automatically.	Load twinkle	Load indicator twinkle fast
E8	Overload	Please check the load power whether exceed the controller's rate power. After decrease the load then long press the key or hold on it will recover automatically.	Load twinkle	Load indicator twinkle slow
Е9	Battery overheat	Please check the battery temperature overheat or not. Place the controller to ventilation environment. Controller will close charging and auto recover after temperature decrease.	Bat twinkle	Solar pane indicator twinkle fast

12. Parameters instruction

Parameter	Value
System voltage	12V/24V/36V/48V
Rate charging current	45A/30A
Rate load current	45A/30A
No load loss	<12mA
Charging circuit voltage drop	Less or equal0.5V
Discharge circuit voltage drop	Less or equal0.5V
Solar input voltage	<140V
Re-entrant boost charge mode voltage	13.2V ×2/24V; ×3/36V; ×4/48V
Over voltage protection	17.0V ×2/24V; ×3/36V; ×4/48V
limited voltage for charging	15.5V ×2/24V; ×3/36V; ×4/48V
Equal charging voltage	Boost charge voltage+0.5V
Equal charging interval	30days
Direct charge voltage	14.4V ×2/24V; ×3/36V; ×4/48V
Float charge voltage	13.6V ×2/24V; ×3/36V; ×4/48V
Over discharge voltage	11.0V ×2/24V; ×3/36V; ×4/48V
Over discharge recover voltage	12.5V ×2/24V; ×3/36V; ×4/48V
Equal charging time	1H
Boost voltage charging time	2Н
Temperature compensation	-3.0mv/°C/2V
Light-control voltage	5V ×2/24V; ×3/36V; ×4/48V
Light control delay	10min
Controller over-temperature protection	>90°C
Battery over-temperature protection	>55°C
Working temperature	-35°Cto+85°C
Control method	Charging: PWM
Time of lcd back- light auto shut down	30(s)
Data auto transfer time	3(s)
Time of Led lattice closed	25(s)
Weight	1.08Kg/45A,0.9Kg/30A

13. Accessories

Temperature probe	lpcs
Screwdriver.	lpcs
Instruction manual	1pcs

14. Warranty

Dear Customers,

Many thanks for selecting products from Cosuper. In order to extend better service to you, pls read our product manual carefully and keep warranty card. Welcome to log in www.cosuper.com to enjoy full scale support and service.

The products are under strict inspection before delivery. We offer 18 month limited warranty:

I In the warranty period, we will provide free repair and service parts when the machine is under normal use.Damaged parts shall be owned by Cosuper.

II The following cases are not covered under warranty.

1 Change the company trademark unauthorized

2 Damage due to misoperation, negligence use, and irresistible factors

3 Repair, modification or remove the label unauthorized